


NOTES

- An eight-way expanding anchor may be used as an acceptable alternate to power installed helical screw anchor.
- 2. If anchor hole diameter is greater than nominal diameter of folded anchors, a 5' (ft) cover of 6" (in) to 12" (in) size rock shall be tamped in to replace the disturbed soil immediately above the anchor.
- 3. See Standard Plans J-27.10 and J-27.15 for Type IV or Type V Strain Pole details not shown.
- 4. Strandvise or Guy Wrap may be used.

RAKE TABLE	
POLE CLASS	RAKE
1900#	7"
2700#	6"
3700#	5"
4800#	5"
5400#	4"
4300#	4"
7200#	4"
ALL TIMBER	6"



INSTALLATION

SPAN WIRE

STANDARD PLAN J-15.15-01

SHEET 1 OF 1 SHEET

APPROVED FOR PUBLICATION

STATE DESIGN ENGINEER

Washington State Department of Transportation